


REV	DESCRIPTION	DATE	BY
1	ADDED TERMINAL BLOCK AND WIRE COLORS; UPDATE DWG	25JUL16	WJR
2	UPDATED RECTIFIER BOARD TO 22100; 24VAC/24VDC	11FEB19	WJR



NOTES:  
 FEEDBACK POTENTIOMETER AND LIMIT SWITCHES ARE PRESET AT THE FACTORY AND DO NOT REQUIRE ADJUSTMENT. ADJUST THE OPEN AND CLOSE OF THE VALVE USING THE ZERO (4mA) AND SPAN (20mA) POTS ON THE CONTROLLER BOARD.

SEE MANUAL FOR CONTROLLER S1 SWITCH SETTINGS. SETTINGS ABOVE ARE FOR NORMAL CONTROL FUNCTION, 4-20mA CONTROL SIGNAL AND MOTOR OFF IF COMMAND SIGNAL IS LOST (STANDARD). OPERATING VOLTAGE = 10-30VDC.

RECTIFIER BOARD IS SINGLE PHASE BRIDGE WITH CAPACITOR.

**IC<sub>I</sub>** Indelac Controls, Inc.  
 Florence, Ky. 41042

WIRING DIAGRAM, 24VAC ELECTRIC ACTUATOR WITH 4-20mA POSITIONER, 4-20mA TRANSMITTER & OPTIONAL 2 AUXILIARY SWITCHES, HEATER/THERMOSTAT & BRAKE

JLR	10-09-2006	<b>W061009</b>
-----	------------	----------------

