



SW. #4	OPEN AUXILIARY SWITCH
SW. #3	CLOSE AUXILIARY SWITCH
SW. #2	OPEN LIMIT SWITCH
SW. #1	CLOSE LIMIT SWITCH

SWITCH LAYOUT

OPTIONAL HEATER & THERMOSTAT

NOTES:
 POWER TO TERMINALS ONE & TWO OPENS THE VALVE (CCW ROTATION)
 POWER TO TERMINALS ONE & THREE CLOSSES THE VALVE (CW ROTATION)
 TERMINALS 4 & 5 FOR LIGHT INDICATION
 TERMINALS 6 THROUGH 11 FOR AUXILIARY SWITCHES.
 TERMINAL 12 & 1 FOR HEATER & THERMOSTAT.

WIRING DIAGRAM DEPICTS THE ACTUATOR IN THE OPEN POSITION

NO	REVISION	DATE	BY
IC_I Indelac Controls, Inc. Florence, Ky. 41042			
WIRING DIAGRAM FOR 12 or 24VDC ACTUATOR WITH TWO AUXILIARY SWITCHES (OPTIONAL), HEATER & THERMOSTAT (OPTIONAL) AND MECHANICAL TORQUE SWITCH.			
JLR	2-10-2011	W110210	

FIELD WIRING

SPDT SWITCH SHOWN FOR ILLUSTRATION ONLY

LIGHTS FOR REMOTE POSITION INDICATION

12 OR 24VDC